

# AMENDMENT OF SOLICITATION/MODIFICATION OF SUBCONTRACT

1. AMENDMENT NO. 0002	2. EFFECTIVE DATE December 15, 2003	3. Page 1 of 2
--------------------------	--	----------------

4. ISSUED BY: **Fluor Fernald, Inc.**  
**P.O. Box 398704**  
**Cincinnati, OH 45239-8704**

5. NAME AND ADDRESS OF SUBCONTRACTOR ( <i>Name, street, county, state, and zip code</i> )	6. AMENDMENT OF SOLICITATION NO. F04PB13013	DATE 11/20/2003
	7. MODIFICATION OF SUBCONTRACT NO.	DATE

## 8. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

x The above numbered solicitation is amended as set forth in Item 10. The hour and date specified for receipt of Offers G is extended, x is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods:

(a) By completing Items 5 and 11, and returning an original and five copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate [ ] letter [ ] telegram [ ] facsimile which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by [ ] telegram or [ ] letter or [ ] facsimile, provided each makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

## 9. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF SUBCONTRACTS/ORDERS. IT MODIFIES THE SUBCONTRACT/ORDER NO. AS DESCRIBED IN ITEM 10.

A. THIS UNILATERAL MODIFICATION IS ISSUED PURSUANT TO: (*Specify authority*). THE CHANGES SET FORTH IN ITEM 10 ARE MADE IN THE SUBCONTRACT IDENTIFIED IN ITEM 7.

B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES SET FORTH IN ITEM 10.

C. THIS BILATERAL MODIFICATION IS ENTERED INTO PURSUANT TO AUTHORITY OF:

D. OTHER (*Specify type of modification and authority*)

E. IMPORTANT: CONTRACTOR is not is required to sign this document and return \_\_\_\_\_ copies to the issuing office.

## 10. DESCRIPTION OF AMENDMENT/MODIFICATION

The purpose of this Amendment is to provide answers to Questions 35 through 37. Based on the Questions and Answers, Revision No. 01 of the Drawings and Specifications will be provided when available.

Except as provided herein, all terms and conditions of the document 6 or 7, remain unchanged and in full force and effect.

11A. NAME AND TITLE OF SIGNER ( <i>Type or print</i> )		12A. Fluor Fernald, Inc.	
11B. SUBCONTRACTOR/OFFEROR   <i>(Signature of person authorized to sign)</i>	11C. DATE SIGNED	12B.   <i>(Signature)</i>	12C. DATE SIGNED

35. ES-C-020, 6.1.4: Spec states "difference between the maximum and minimum inside diameters of the vessel shall not exceed 1/2". The drawing tolerance is plus 0/minus 1/4". Which governs?

**Answer:** The OD as dimensioned 76 3/4" +0 -1/4" is the governing dimension's, any out of roundness must fall within the 1/4" total tolerance. The spec/dwg will be revised to clarify.

36. Dwg C-065-166031-002, sheet 1 of 2: Due to the "Section View", technically the 3/8" bevel weld of item 1 and 2 to item 3 is on the inside of the container. Is this what was intended? Can this weld be on the outside? (This can have an important cost implication)

**Answer:** Technically, this was not the intended meaning, all the prototypes were built with the bevel weld from the outside as was intended, the arrowhead on the weld symbol will be relocated on the drawing so there will not be any misinterpretation of the meaning.

37. Dwg C-065-166031-002, sheet 1 of 2: Note 3 allows consideration of alternatives for the "Grapple Ring". Is it possible to get information related to the "grapple" device in order to properly consider an alternative design?

**Answer:** The drawing note does not allow consideration for alternatives to the grapple ring, what it says is the grapple ring is required to be an angle that is 1/2" x 2" x 4", the designer knows that this is not a standard size, so the note was added that if preferred, the vendor may chose to produce a 1/2 x 3 x 4 angle and cut it down to 1/2 x 2 x 4, or use a 1/2 x 2 x 2 angle and roll 2" flat bar to extend the one leg to 4" length. Information of the grapple would not benefit in this matter.